



KARNATAKA STATE FIRE AND EMERGENCY SERVICES



Office of the District Fire Officer, Sunkadakatte Fire Station, Channenahalli, Magadi
Main Road, Bengaluru-562 130. © 080-29554101.

No.20/ FSCR/DFO/SKFS/2022.

Date:10-12-2022.

"Annexure-2"

To,
The Authorized Signatory
M/s. Gangothri International Public School
Block-A, Venkateshwara Farm,
Rajivgandhi Nagar,
Vishwanedam Post,
Near Sunkadakatte,
Bengaluru-560 091.

Sir,

Sub : Issue of "Fire Safety Compliance Report" with respect to fire prevention, firefighting and evacuation measures maintained at M/s. Gangothri International Public School, Block-A, Venkateshwara Farm, Rajivgandhi Nagar, Vishwanedam Post, Near Sunkadakatte, Bengaluru - reg.

Ref : 1) This Office FSR No. 20/FSR/DFO/SKFS/2022, Date:08-12-2022.
2) Your request letter dated: 09-12-2022.

><<<*@*<<<<

With reference to the above cited subject, as per reference(1) a conditional Fire Safety Recommendation was issued to the premises of at "**M/s. Gangothri International Public School, Block-A, Venkateshwara Farm, Rajivgandhi Nagar, Vishwanedam Post, Near Sunkadakatte, Bengaluru-560 091**" with a condition to fulfill the recommendations and compliance the same within 3 months.

With reference cited (2) above, the management of "**M/s. Gangothri International Public School**" had requested for the fire safety compliance report from our department. In this regard the above school building was re-inspected by Fire Station Officer, Sunkadakatte Fire Station on 10-12-2022 and submitted the report & recommended to issue Compliance Report.

Aparna Dayaravi
PRINCIPAL

GANGOTHRI INTERNATIONAL PUBLIC SCHOOL
CBSE Affiliation No. 830319
Block-A, Gangothri Campus, Venkateshwara Farm,
Rajiv Gandhi Nagar, VN Post, Bengaluru-560091

[Signature]
SECRETARY

GANGOTHRI EDUCATION TRUST
Block-A, Gangothri Campus, M/S
Venkateshwara Farm, Rajivgandhi Nagar,
VN Post, Bengaluru - 560 091.



Under the above circumstance the Karnataka State Fire & Emergency Services Department is issuing the "Fire Safety Compliance Report" to "M/s. Gangothri International Public School, Block-A, Venkateshwara Farm, Rajivgandhi Nagar, Vishwaneedam Post, Near Sunkadakatte, Bengaluru-560 091" subject to proper maintenance of firefighting installations in the good working conditions and arrange for 40% of staffs/employees training within 03 months from the date of issue of this report.

"This Fire Safety Compliance Report is valid for Only One Year from the date of issue and it is renewable".

Yours faithfully
[Signature]
District Fire Officer (Fire Prevention)
Karnataka State Fire & Emergency Services,
Sunkadakatte Fire Station,
Bengaluru-562 130.

[Signature]
PRINCIPAL
GANGOTHRI INTERNATIONAL PUBLIC SCHOOL
CBSE Affiliation No. 830319
Gangothri Campus, Venkateshwara Farm,
Gandhi Nagar, VN Post, Bangalore-560091

[Signature]
SECRETARY
GANGOTHRI EDUCATION TRUST®
Block-A, Gangothri Campus, M/S
Venkateshwara Farm, Rajivgandhi Nagar,
VN Post, Bangalore - 560 091.



KARNATAKA STATE FIRE AND EMERGENCY SERVICES



Office of the District Fire Officer, Sunkadakatte Fire Station, Channenahalli, Magadi Main Road,
Bengaluru-562 130. © 080-29554101.

No.21/FSR/DFO/SKFS/2022.

Date:08 -12-2022.

ANNEXURE-1

Group- B Educational Building

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory).

To,
The Authorized Signatory
M/s. Gangothi International Public School
Block-A, Venkateshwara Farm,
Rajivgandhi Nagar,
Vishwaneedam Post,
Near Sunkadakatte,
Bengalure-560 091.

Sir,

Sub : Issue of 'Fire Safety Recommendation' for low rise educational building constructed & occupied at M/s. Gangothi International Public School, Block-A, Venkateshwara Farm, Rajivgandhi Nagar, Vishwaneedam Post, Near Sunkadakatte, Bengaluru-reg.


Ref : Your request letter dated 29-11-2022.

<◇◇◇*@*◇◇◇>


With reference to the subject cited above, the premises of M/s. Gangothi International Public School situated at Block-A, Venkateshwara Farm, Rajivgandhi Nagar, Vishwaneedam Post, Near Sunkadakatte, Bengaluru-560 091 was inspected by Fire Station Officer, Sunkadakatte Fire Station on 07-12-2022 with respect to Fire prevention, Firefighting and Evacuation measures to be complied in the above premises and has submitted the details as under;

A. Details of the building / premises :-

01)	Name and Address of the Applicant.	:	The Authorized Signatory M/s. Gangothi International Public School Block-A, Venkateshwara Farm, Rajivgandhi Nagar, Vishwaneedam Post, Near Sunkadakatte, Bengalure-560 091.
-----	------------------------------------	---	---




02)	Name and Address of the premises.	:	M/s. Gangothri International Public School Block-A, Venkateshwara Farm, Rajivgandhi Nagar, Vishwaneedam Post, Near Sunkadakatte , Bengalore-560091.
03)	Name and address of the Building owner	:	The Authorized Signatory M/s. Gangothri International Public School Block-A, Venkateshwara Farm, Rajivgandhi Nagar, Vishwaneedam Post, Near Sunkadakatte, Bengalore-560091.
04)	Number of buildings	:	One Building
05)	Number of floors	:	Cellar, Ground and 02 Upper floors.
06)	Floor-wise details of occupancy:-		
	Cellar	:	Physic Laboratory, Chemistry Laboratory, Biology Laboratory, AV room, Dance room, and Staff room.
	Ground floor	:	Chairman room, Principal room, Conference room, GYM room, Fun room, Math's Lab, Staff room, Pantry, Record room, 02-Store rooms, Waiting Lounge, Counselor room, Computer lab, 02-Gents and Ladies Toilet rooms.
	1 st Floor	:	02-Office rooms, 09-Class rooms and 02 Gents and Ladies Toilet rooms.
	2 nd floor	:	Office room, 09-Class rooms, 02-Gents and Ladies Toilet rooms.
07)	Height of the building	:	11.00 mtrs.
08)	Site area	:	10 acres
09)	Built-up area of each floor:-		
	Cellar	:	584.86 Sq.mtrs
	Ground floor	:	637.58 Sq.mtrs
	1 st floor	:	612.30 Sq.mtrs
	2 nd floor	:	612.30 Sq.mtrs
10)	Total built-up area	:	2447.04 Sq.mtrs
11)	Surrounding properties: -		
	East(front)	:	10.00 mtrs wide existing non Residential road
	West(Rear)	:	Residential building




	North(Side) :	Residential Building
	South(Side) :	Educational building

B. On inspection of this Educational premises, the following fire prevention, firefighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-


Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)																		
01)	Accessibility to the premises	The Premises is accessible from 10.00 mtrs. existing non Residential road located on the eastern side and the road is hardened to carry the load of 45,000 kgs.	Adequate.																		
02)	No. of Entrances	01 no. of Entrances have been provided.	Complied.																		
03)	Width of Entry / Exit	01 no. of Entrance/Exit 6.00 mtrs. width have been provided.	Complied.																		
04)	Diesel generators.	01 no. of 82.5 KVA capacities have been provided & it should be connected to provide service to all the emergency provisions in building.	Complied.																		
05)	No. of staircases Available	<table border="1"> <tr> <td>No. of Staircases</td> <td>:</td> <td>02 nos.</td> </tr> <tr> <td>Width of staircases.</td> <td>:</td> <td>Each of 1.50 mtrs</td> </tr> <tr> <td>Width of treads</td> <td>:</td> <td>Each of 30 Cms</td> </tr> <tr> <td>Height of risers</td> <td>:</td> <td>Each of 15 Cms</td> </tr> <tr> <td>No. of riser per flight.</td> <td>:</td> <td>Each of 8 nos.</td> </tr> <tr> <td>Height of handrails.</td> <td>:</td> <td>Each of 0.90 mtrs.</td> </tr> </table>	No. of Staircases	:	02 nos.	Width of staircases.	:	Each of 1.50 mtrs	Width of treads	:	Each of 30 Cms	Height of risers	:	Each of 15 Cms	No. of riser per flight.	:	Each of 8 nos.	Height of handrails.	:	Each of 0.90 mtrs.	Complied.
No. of Staircases	:	02 nos.																			
Width of staircases.	:	Each of 1.50 mtrs																			
Width of treads	:	Each of 30 Cms																			
Height of risers	:	Each of 15 Cms																			
No. of riser per flight.	:	Each of 8 nos.																			
Height of handrails.	:	Each of 0.90 mtrs.																			
06)	Fire extinguisher	<p>the building. The details as indicated below.</p> <table border="1"> <tr> <td>Floors</td> <td>ABC</td> <td>CO₂</td> </tr> <tr> <td>Details</td> <td>4 kgs</td> <td>4.5 kg</td> </tr> <tr> <td>Cellar</td> <td>04</td> <td>02</td> </tr> <tr> <td>Ground</td> <td>05</td> <td>-</td> </tr> </table>	Floors	ABC	CO ₂	Details	4 kgs	4.5 kg	Cellar	04	02	Ground	05	-	Complied.						
Floors	ABC	CO ₂																			
Details	4 kgs	4.5 kg																			
Cellar	04	02																			
Ground	05	-																			



		Floor			
		1 st Floor	04	---	
		2 nd Floor	04	--	
		Total	13	02	
07)	First aid Hose Reel Hose.	One Hose Reel Hose near each staircase the hose reel hose of Minimum 19 mm size of adequate length to reach the farthest point of each floor have been provided. shut off branch having a nozzle of 5 mm size. The hose reel hose have been connected at each landing.			Complied.
08)	Terrace tank over respective tower terrace.	Terrace tank of 10,000 liters capacity and underground tank of 10,000 liters capacity has been provided.			Complied.
09)	At the terrace tank level with minimum pressure of 3.5 kg/Cm ²	The system is connected to a Booster pump of 450 lpm capacity.			Complied.
10)	Escape routes	"Exits & Emergency Exit" Signage's written in bold letters marked in luminous paints have been indicated in the corridor/passage on each floor as a guide during evacuation near the staircases and near exits in each floor of this building.			Complied.
11)	Fire order	A notice board indicating the action to be taken by the employees in case of an emergency with telephone number of Sunkadakatte Fire Station i.e. 080-28434101 & fire Control room nos. 080-22971600, 550, 500 & 101 telephone numbers of nearest Ambulance Services etc.			Complied.



12)	No Smoking Board	COTPA Sec-4 direction No Smoking area smoking is an offence board have been provided and written in English & Kannada both languages have been prominently displayed at inside the entry/exit of each floor.	Complied.
13)	Nominate one Fire Nodal Officer	----	A Fire nodal officer Shall be nominated either from teaching or non teaching staff .
14)	Firefighting training	Not imparted.	40% of the employees should be trained in fire prevention & Fire Fighting at the R.A. Mundkur fireand Emergency Services Academy, B.G Road, Bengaluru.
15)	<p><u>General Fire precaution measures :-</u></p> <p>A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.</p> <p>B. Accumulation of combustibile waste in and around the premises should be avoided.</p> <p>C. The exit ways shall be always kept clear without any obstruction.</p> <p>D. Liquefied petroleum gas should be not stored in the building.</p> <p>E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction.</p> <p>F. During the class hours the class room doors shall not be locked from inside to outside.</p> <p>G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14th of every year by conducting fire safety drills with co-ordinate with Fire Service Department.</p> <p>H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.</p>		



Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing 'Fire Safety Recommendation' to M/s. **Gangothri International Public School** situated at Block-A, Venkateshwara Farm, Rajivgandhi Nagar, Vishwaneedam Post, Near Sunkadakatte, Bengaluru-560 091 subject to condition and compliance of the above recommendations in column-4 of part-B within 3 months and compliance to the undersigned.

This "Fire Safety Recommendation" is valid for **Only One Year** from the date of issue and it is renewable.

All requirements recommended above are as per National Building Code 2016 Part-4 clause 3.1.8 of Fire and Life safety will have to be complied with Mandatorily.

Yours faithfully

M. S. M. S.
District Fire Officer (Fire Prevention)
Karnataka State Fire & Emergency Services,
Sunkadakatte Fire Station,
Bengaluru-562 130.

Aparna B. Jayaravi
PRINCIPAL

GANGOTHRI INTERNATIONAL PUBLIC SCHOOL
CBSE Affiliation No. 830319

Block-A, Gangothri Campus, Venkateshwara Farm,
Rajivgandhi Nagar, VN Post, Bangalore-560091

[Signature]
SECRETARY

GANGOTHRI EDUCATION TRUST
Block-A, Gangothri Campus, M/S
Venkateshwara Farm, Rajivgandhi Na
VN Post, Bangalore - 560 091.